



# 产品认证证书


证书编号: CQC2002010308025029

申请人名称及地址

浙江天正电气股份有限公司  
浙江省乐清市柳市镇苏吕工业区

制造商名称及地址

浙江天正电气股份有限公司



浙江省乐清市柳市镇苏吕工业区

生产企业名称及地址

浙江天正电气股份有限公司 (V024163)  
浙江省乐清市柳市镇柳乐路 332 号

产品名称和系列、规格、型号

刀型触头熔断器

RT16Z-A3,RT16Z-A3G,RT16Z-3G,RT16Z-3,RT16-A3,RT16-A3G,RT16-3G,RT16-3; 参数详见附件

产品标准和技术要求

GB/T 13539 2-2015

主任:



## 中国质量认证中心

中国 北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

C 0376988



**CERTIFICATE NO.: CQC2002010308025029**

**NAME AND ADDRESS OF THE APPLICANT**

Zhejiang Tengen Electric Co.,Ltd.  
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

**NAME AND ADDRESS OF THE MANUFACTURER**

Zhejiang Tengen Electric Co.,Ltd.  
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

**NAME AND ADDRESS OF THE FACTORY**

Zhejiang Tengen Electric Co.,Ltd. (V024163)  
No.332 Liule Road, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

**PRODUCT NAME, MODEL AND SPECIFICATION**

Fuses with fuse-links with blade contacts  
RT16Z-A3,RT16Z-A3G,RT16Z-3G,RT16Z-3,RT16-A3,RT16-A3G,RT16-3G,RT16-3; See the Appendix

**THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS**

GB/T 13539.2-2015

**TYPE OF CERTIFICATION SCHEMES**

Type testing+Follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462141-2019 .

Valid from: Aug.24,2020

Valid until: Nov.20,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

**President:**

Lu Mei



**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China  
<http://www.cqc.com.cn>

C 0376988



# 产品认证证书

附 录

第 1 页 共 1 页

证书编号: CQC2002010308025029

纸 号: 376988

熔断体型号

RT16Z-A3,RT16Z-A3G,RT16Z-3G,RT16Z-3,RT16-A3,RT16-A3G,RT16-3G,RT16-3,

熔断体的额定电压 Un: AC500V/AC690V,DC440V;

熔断体的额定电流 In: 315A,400A,500A,630A(AC500/690V,DC440V),800A(AC690V);

额定短路能力 I1: 315-630A:120kA/AC500V,50kA/AC690V,100kA/DC440V;

800A:100kA/AC690V;

分断范围和使用类别: gG;

熔断器支持件型号: RT16- 3,RT16Z- 3;

熔断器支持件的额定电压 Un: AC690V(RT16- 3,RT16Z- 3),DC440V(RT16Z- 3);

熔断器支持件的额定冲击耐受电压 Uimp: 6kV;

熔断器支持件的额定电流 In: 800A;

极数: 1P.

主任:

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

