

品

II型自愿认证

证书编号: CQC2002010308025024



委托人名称及注册地址 浙江天正电气股份有限公司
浙江省乐清市柳市镇苏吕工业区


制造商名称及注册地址 浙江天正电气股份有限公司
浙江省乐清市柳市镇苏吕工业区

生产企业名称及生产地址 浙江天正电气股份有限公司
浙江省乐清市柳市镇柳乐路 332 号

产品名称和系列、规格、型号 刀型触头熔断器
RT16(Z)-(A)00;详见附件

产品标准和技术要求 GB/T 13539.2-2015

认证模式 产品型式试验+初次工厂检查+获证后监督



可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息

授权签字人 签发

陈昕 陆楠

中国质量认证中心



CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2002010308025024

Valid from: Aug.24,2020

Valid until: May.20,2031

NAME AND REGISTERED ADDRESS OF THE APPLICANT Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

NAME AND LOCATION OF THE FACTORY Zhejiang Tengen Electric Co.,Ltd.
No.332 Liule Road, Liushi Town, Yueqing City, Zhejiang Province, P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION Fuses with fuse-links with blade contacts
RT16(Z)-(A)00;See the appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS GB/T 13539.2-2015

TYPE OF CERTIFICATION SCHEMES Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.
The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

For more information is available through the QR code below or CNCA's website: www.cnca.gov.cn.

SIGN BY

SIGNATURE

CHINA QUALITY CERTIFICATION CENTRE



产品认证证书

II型自愿认证

附 录

证书编号: CQC2002010308025024

第 1 页 共 1 页

纸 号: 56307

RT16(Z)-(A)00;

熔断体:

Un: AC500/AC690V (RT16-00, RT16-A00),

AC500/AC690V, DC250V/DC440V (RT16Z-00, RT16Z-A00);

In: 2A, 4A, 6A, 8A, 10A, 16A, 20A, 25A, 32A, 40A, 50A, 63A, 80A, 100A, 125A, 160A;

额定分断能力(I1): 120kA/AC500V, 50kA/AC690V, 100kA/DC250V, 50kA/DC440V;

分断范围和使用类别: gG

熔断器支持件:

Un: AC500/AC690V (RT16-00, RT16-A00), AC500/AC690V /DC440 (RT16Z-00, RT16Z-A00);

In: 160A;

1P;

峰值耐受电流: 120kA/AC500V, 50kA/AC690V, 100kA/DC250V, 50kA/DC440V

注: 此附录与证书同时使用时有效。



中国质量认证中心

